

FM1 Chilled Water Bridge Campus Chilled Water Supply Temp GE BAS Sensing DF868 4-20maDC Campus Chilled Water Return Temp Controlle Т Campus Chilled Water Flow Controlle TE Chilled Water Return NSIT **Rack Mounted** Data Jack From Campus Chilled water bridge 30 ton hour Т pumps other valves, per pulse gauges and transmitters TE **Chilled Water Supply** not shown. FM₁ **Metering Panel** 5D 10D Ultrasonic Straight Flow Straight Square D ION Meter 4-20ma Rack Mounted **NSIT** From Steam Data Jack FM 2 Campus -**Annubar** 1 pulse = 10 gallons To Campus ← FM 3 TT = Transmitter Device Niagara **TE = Temperature Element** Turbine Building Condensate Flow Meter Receiver