

Chilled Water Meter

		Flow Range	Supply Temp	Return Temp	Piping Size	Pressure	Remarks	Instrument Type
FM 1	Chilled Water Meter GE Sensing DF868	0-600 gpm	45°F	59°F	6 inch	40-120 psig		Ultrasonic Turbine
FM 2	Steam Meter Rosemount 3095MV flow meter with an Annubar (Rosemount	0-6,000 lbs/hr	Saturated to 45°F superheat	————		80 psig	Temp compensation for superheat	Annubar Vortex
FM 3	Condensate Meter Niagara WPX 210	12 gpm Steady state; 30 gpm transient						Turbine

*All values are nominal; actual may vary.