

## **PLAN NOTES**

- BYPASS VALVE IS NORMALLY CLOSED. VALVE IS OPENED TO RUN OFF CTE DISTRICT PRESSURE DIFFERENTIAL IF BUILDING PUMPS ARE INOPERATIVE.
- 2) ROTATE VALVE 45° FROM VERTICAL. VERIFY WITH MANUFACTURERS WRITTEN INSTALLATION INSTRUCTIONS FOR ACTUATOR.
- (3) 3/4" VALVE WITH HOSE END CAPPED.
- (4) 6" DIAL PRESSURE GAUGE, 0-160 PSIG RANGE.
- 5 SUPPORT FROM FLOOR. INSULATE FIRST 12" OF PIPE SUPPORT BELOW PIPE WITH ELASTOMERIC. ANCHOR SUPPORT TO FLOOR AND GROUT FLOOR PLATE, SEE DETAIL.



