

1/2" DIAMETER
BLACK PLASTIC HOSE

PLASTIC FLAGGING
ON EACH WIRE

GALVANIZED WIRE

SET TOP OF ROOT BALL
1"-2" HIGHER THAN
SURROUNDING GRADE

3" HIGH SOIL BERM
BEYOND EDGE OF ROOT BALL

3" THICK MULCH RING, 6' (DIA)
MINIMUM DO NOT PLACE MULCH IN
CONTACT WITH TREE TRUNK.

(3) - (2"x2"x36") HARDWOOD
STAKES EQUALLY SPACED

TAMP SOIL AROUND ROOT BALL BASE
FIRMLY WITH FOOT PRESSURE SO
THAT ROOT BALL DOESN'T SHIFT

FOR FALL INSTALLATIONS ONLY, BREATHABLE
FABRIC TREE WRAP APPLIED FROM TRUNK
FLARE TO FIRST BRANCH. WRAP FABRIC
FROM THE BOTTOM UP WITH SUFFICIENT
OVERLAP TO COVER ALL BARK.
REMOVE NO LATER THAN 12 MONTHS AFTER
PLANTING.

EACH TREE MUST BE PLANTED SUCH THAT
THE TRUNK FLARE IS VISIBLE AT THE TOP
OF THE ROOT BALL. TREES WHERE THE
TRUNK FLARE IS NOT VISIBLE SHALL BE
REJECTED. DO NOT COVER THE TOP OF THE
ROOT BALL WITH SOIL.

BACKFILL PLANTING HOLE WITH
SOIL MIXTURE AS SPECIFIED

FINISHED GRADE


1:1 SLOPE ON SIDES OF PLANTING HOLE

REMOVE ALL BINDINGS AND BURLAP FROM
TOP 1/3 OF ROOT BALL. IF PLANT IS
SHIPPED WITH A WIRE BASKET, CUT THE
WIRE BASKET IN FOUR PLACES AND FOLD
DOWN INTO PLANTING HOLE.

PLACE ROOT BALL ON
UNEXCAVATED OR COMPACTED SOIL

NOTES:

1. CONTRACTOR SHALL VERIFY THAT PLANTING HOLE IS FREE DRAINING PER SPECIFICATION PRIOR TO PLANTING.
2. DO NOT HEAVILY PRUNE THE TREE AT PLANTING. PRUNE ONLY CROSSOVER LIMBS, CO-DOMINANT LEADERS, AND BROKEN OR DEAD BRANCHES.
3. MARK THE NORTH SIDE OF THE TREE IN THE NURSERY, AND ROTATE TREE TO FACE NORTH.



DECIDUOUS TREE PLANTING DETAIL

NO SCALE