



PLAN NOTES

- ① PROVIDE BUTTERFLY VALVES IN LIEU OF BALL VALVES WHEN PIPE SIZES ARE ABOVE 2". (TYPICAL)
- ② INSTALL AT LOWEST POINT IN PIPING.
- ③ INSTALL MODULATING VALVE SO THAT STEM IS VERTICAL.
- ④ REFER TO PLANS AND SCHEDULES FOR QUANTITY OF COILS IN COIL BANK. EACH COIL TO BE PIPED SEPARATELY AS SHOWN.
- ⑤ THERMOMETERS TO BE PROVIDED ONLY FOR AHU COILS.

A 2-WAY MULTIPLE WATER COIL PIPING DETAIL
NO SCALE

